

Return to:
 Messe München GmbH
 Hauptabt.
 Techn. Ausstellerservice
 Messegelände
 81823 München
 Germany
 Phone: +49 (0) 89 949 - 2 11 24
 Fax: +49 (0) 89 949 - 2 11 29

Sprinkler Installation in the Halls

5.3

Page 1 of 2

Exhibitor
Street/P.O.Box
Country, Town, Postcode

GOLF EUROPE 2008	
Hall Stand no.	Outdoor exhibition area Block
Contact	
Phone with area code and ext.	Fax with area code and ext.
E-mail	

The installation of a **sprinkler system** is required **if the covered stand area is more than 30 m²** (see "Two-Storey Stand Construction" and form 1.2 "Application for Preventive Fire Protection Measures").

We hereby order, in the name and on behalf of the above mentioned exhibitor, subject to the conditions for connection and supply of sprinkler systems detailed on page 2:

Item. no.	Please tick	Description	EUR
38497		Sprinkler main connection (basic installation incl. 3 sprinkler nozzles)	1,029.00

Item. no.	Quantity	Description	EUR/each
38499		Additional sprinkler nozzles	258.90

The precise number and position of the sprinkler nozzles is determined after submission of the stand drawing.

Additional sprinkler nozzles can be employed to enlarge the basic installation to a maximum of 18 sprinkler nozzles.

Please note:

The sprinkler pipes are not suitable for visible exposure.

We will be installing a rostrum at our stand:

- Yes**, the clearance height between the floor of the hall and the rostrum is approx. _____ cm
 No

Please be sure to submit scale plans marked accordingly (with arrow showing north as well as neighbouring stands or other points of reference).

MMG reserves the right to charge an additional fee for late orders and plans.

Place, date
Company stamp and legally binding signature of exhibitor

2008



Connection and supply conditions for sprinkler systems

Sprinkler systems must be installed according to the recognized rules of technology and with the approval of the Munich Municipal Fire Department.

The prices listed apply to installation heights of up to 3 m. Any additional costs incurred for installation heights of over 3 m and for special stand constructions (surface installations, bypassing of summers and stand components, etc.) are charged for.

The complete documents (as described in form 1.3), orders and plans must be submitted to Messe München GmbH by the specified deadline at the latest (see "Important Notes"), however, for two-storeyed and covered stands not later than 6 weeks before the start of construction.

No guarantee can be given that installations ordered after this date will be completed on time.

MMG reserves the right to charge an additional fee for late orders.

The sprinkler pipes are installed in the halls according to the dimensions specified in the plan. The position of the shut-off valve on the ground floor must be specified. The supply pipe will be laid if possible in the utility conduits but may be laid above ground if the position of the shut-off valve and the following sprinkler installation require this (upon request, we will indicate the placement of the basic sprinkler pipe/outlet). The sprinkler installation itself is always installed in front of the walls and under the suspended ceilings. The pipes and the sealed shut-off valve must remain accessible at all times and must not be built over or moved.

The exhibitor shall be liable for damage resulting for non-compliance with this regulation.

The General Terms of Contract for Exhibitor Services of Messe München GmbH shall apply additionally.

Design data:

Exhibition halls in accordance with VDS are in fire risk class BG 2.3.

Maximum protection area per sprinkler nozzle 12 m² by means of glass bulb sprinkler DN 15, nominal opening temperature 68°C, colour red.

Separate cabins and rooms must also be provided with sprinklers in conformance to the maximum protection area of 12 m²/nozzle.

A maximum of 18 sprinkler nozzles may be connected for each DN 50 connecting pipe in the utilities conduit. The pipe dimension of feeder pipes to the nozzles is also DN 50.